



50-23 Twenty-Third Street  
Long Island City, NY 11101  
Tel: 718-729-7200 • Fax: 718-729-8677  
[www.metrogroupinc.com](http://www.metrogroupinc.com)

December 2, 2010

East River Housing  
575 Grand Street  
New York, NY 10002  
Attn: Tom Gibbons

Re: Lead Testing Results for the Domestic Water Lines at 575 Grand Street

Dear Mr. Gibbons,

Attached please find the results from lead analysis performed on the sample from your building at 575 Grand Street. This sample obtained from the Laundry Room sink cold water distribution line. In drinking water, the MCL (maximum contaminant level) as specified, indicate 5 parts per billion or 0.005 mg/L as an upper limit. The amount measured in this analysis was < 0.001 mg/L (one part per billion).

Based on the sample obtained from your building November 10<sup>th</sup>, 2010, your drinking water has low lead levels, and is safe for consumption.

Please feel free to contact me with any further questions.

Very Truly Yours,

Peggy Ibanez  
Account Executive



# THE METRO GROUP, INC.

*Servicing Water Systems with Environmental Care*

50-23 Twenty-Third Street  
Long Island City, NY 11101  
TEL: (718) 729-7200  
FAX: (718) 729-8677

## CERTIFICATE OF ANALYSIS

### LEAD ANALYSIS

Date: December 2<sup>nd</sup>, 2010

Customer: East River Housing  
575 Grand Street  
New York, New York 10002

Analysis No.: 105369-2  
Representative: Peggy Ibanez  
SAMPLING DATE: November 10<sup>th</sup>, 2010  
SOURCE OF SAMPLE: Laundry Room–Cold 575 Grand St.

Parameters	Source	Unit	Results	Analytical Method	MCL
Lead as Pb	Laundry Room–Cold	mg/L	< 0.001	EPA200.5	5.0 ppb

Comments:

*Pragnesh Kansupada*  
Pragnesh Kansupada  
Chief Chemist

PK:ps