



## LABORATORY REPORT

REPORT NO.: **142699**

CLIENT: **EAST RIVER HOUSING CORP**

SAMPLE DATE: 11/24/14

ADDRESS: 26 Lewis Street  
New York, NY 10002

REPORT DATE: 11/26/14

ATTENTION:

FIELD ENGINEER: Sean Snyder

REFERENCE: BACTERIA ANALYSIS

### COMMENTS:

According to the attached Laboratory Report from EMSL Analytical, Inc., no Total Coliform or *E.Coli* bacteria were detected in water samples drawn on November 24, 2014 from the:

Sample Location	Total Coliform (present/absent)	<i>E. Coli</i> (present/absent)
APT A 401 SINK	Absent	Absent
APT B 2004 SINK	Absent	Absent
APT C 1107 SINK	Absent	Absent
APT E 1701 SINK	Absent	Absent
APT F 1205 SINK	Absent	Absent
APT G 102 SINK	Absent	Absent
APT H 1806 SINK	Absent	Absent
APT J 1002 SINK	Absent	Absent
APT K 105 SINK	Absent	Absent
APT L 1002 SINK	Absent	Absent



APT M 1705 SINK	Absent	Absent
570 GRAND TANK RM	Absent	Absent
575 GRAND TANK RM	Absent	Absent

Yours Truly,

A handwritten signature in black ink, reading "Liz Kinderman", is written over a horizontal line. The signature is cursive and fluid.

Liz Kinderman, Microbiological Support Assistant

**EMSL Analytical, Inc.**

307 West 38th Street, New York, NY 10018  
 Phone/Fax: (212) 290-0051 / (212) 290-0058  
<http://www.EMSL.com> [manhattanlab@emsl.com](mailto:manhattanlab@emsl.com)

EMSL Order: 031445114  
 CustomerID: BAWM25  
 CustomerPO:  
 ProjectID:

Attn: **Nora Rothschild**  
**Barclay Water Management**  
**55 Chapel Street**  
**Newton, MA 02458**

Phone: (603) 508-7001  
 Fax:  
 Received: 11/24/14 12:40 PM  
 Analysis Date: 11/25/2014  
 Collected: 11/24/2014

Project: **PO: 38353; EAST RIVER HOUSING**

**Test Report: Total Coliform (Presence/Absence)**

Method: SM-9223 B for Water Samples

Sample	Sampling Location Date/Time Collected	Amount Received mL	Amount Sampled mL	Total Coliform Present/Absent	<i>E. Coli</i> Present/Absent
031445114-0001 1	APT A 401 SINK 11/24/2014 Prepped 11/24/14 1:27 P.M. Analyzed 11/25/14 1:30 P.M.	120	100	Absent	Absent
031445114-0002 2	APT B 2004 SINK 11/24/2014 Prepped 11/24/14 1:27 P.M. Analyzed 11/25/14 1:30 P.M.	120	100	Absent	Absent
031445114-0003 3	APT C 1107 SINK 11/24/2014 Prepped 11/24/14 1:27 P.M. Analyzed 11/25/14 1:30 P.M.	120	100	Absent	Absent
031445114-0005 5	APT E 1701 SINK 11/24/2014 Prepped 11/24/14 1:27 P.M. Analyzed 11/25/14 1:30 P.M.	120	100	Absent	Absent
031445114-0006 6	APT F 1205 SINK 11/24/2014 Prepped 11/24/14 1:27 P.M. Analyzed 11/25/14 1:30 P.M.	120	100	Absent	Absent
031445114-0007 7	APT G 102 SINK 11/24/2014 Prepped 11/24/14 1:27 P.M. Analyzed 11/25/14 1:30 P.M.	120	100	Absent	Absent
031445114-0008 8	APT H 1806 SINK 11/24/2014 Prepped 11/24/14 1:27 P.M. Analyzed 11/25/14 1:30 P.M.	120	100	Absent	Absent

Analyst(s)

Charlene Kingston (13)

or other approved signatory

Initial report from 11/25/2014 14:35:59

**EMSL Analytical, Inc.**

307 West 38th Street, New York, NY 10018  
 Phone/Fax: (212) 290-0051 / (212) 290-0058  
<http://www.EMSL.com> [manhattanlab@emsl.com](mailto:manhattanlab@emsl.com)

EMSL Order: 031445114  
 CustomerID: BAWM25  
 CustomerPO:  
 ProjectID:

Attn: **Nora Rothschild**  
**Barclay Water Management**  
**55 Chapel Street**  
**Newton, MA 02458**

Phone: (603) 508-7001  
 Fax:  
 Received: 11/24/14 12:40 PM  
 Analysis Date: 11/25/2014  
 Collected: 11/24/2014

Project: **PO: 38353; EAST RIVER HOUSING**

**Test Report: Total Coliform (Presence/Absence)**

Method: SM-9223 B for Water Samples

Sample	Sampling Location	Amount Received	Amount Sampled	Total Coliform	<i>E. Coli</i>
	Date/Time Collected	mL	mL	Present/Absent	Present/Absent
031445114-0009 9	APT J 1002 SINK 11/24/2014 Prepped 11/24/14 1:27 P.M. Analyzed 11/25/14 1:30 P.M.	120	100	Absent	Absent
031445114-0010 10	APT K 105 SINK 11/24/2014 Prepped 11/24/14 1:27 P.M. Analyzed 11/25/14 1:30 P.M.	120	100	Absent	Absent
031445114-0011 11	APT L 1002 SINK 11/24/2014 Prepped 11/24/14 1:27 P.M. Analyzed 11/25/14 1:30 P.M.	120	100	Absent	Absent
031445114-0012 12	APT M 1705 SINK 11/24/2014 Prepped 11/24/14 1:27 P.M. Analyzed 11/25/14 1:30 P.M.	120	100	Absent	Absent
031445114-0013 13	570 GRAND TANK RM 11/24/2014 Prepped 11/24/14 1:27 P.M. Analyzed 11/25/14 1:30 P.M.	120	100	Absent	Absent
031445114-0014 14	575 GRAND TANK RM 11/24/2014 Prepped 11/24/14 1:27 P.M. Analyzed 11/25/14 1:30 P.M.	120	100	Absent	Absent

Analyst(s)

*Charlene Kingston (13)*

John McCauley, Laboratory Manager  
 or other approved signatory

Colilert® is recommended for drinking and clean water samples only. Colilert® can detect coliforms at 1 cfu/100 ml within 24 hours of collection; NA = not applicable. The test results contained within this report meet the requirements of NELAC unless otherwise noted.  
 Samples analyzed by EMSL Analytical, Inc. New York, NY NYS ELAP 11506

Initial report from 11/25/2014 14:35:59